


SOCORRO ELECTRIC COOPERATIVE, INC.  
ORIGINAL RULE NO. 16  
CANCELLING N.M.P.S.C. SHEET NO. 30

CUSTOMERS EQUIPMENT

Page 1 of 1

The customer shall install only such motors, other apparatus, or appliances as are suitable for operation with the character of the service supplied by the Cooperative and which are not detrimental to the Cooperative or other consumers on the Cooperative's system. Further, the electric power must not be used in such a manner as to cause abnormal voltage fluctuation or disturbance to the Cooperative distribution system. The Cooperative may require the installation of approved starting current load limiting devices on motors of more than five (5) horsepower. Upper limits of in-rush starting current tolerance will be determined by the Cooperative.

Advice Notice No. 30

  
Lupe Vega, Manager

EFFECTIVE BY OPERATION OF LAW  
SEC. 62-8-7 AND G. O. NO. 2, SEC. 20

DATE 5/30/85

NEW MEXICO PUBLIC SERVICE COMMISSION

**SERVICE**