

NEW MEXICO WATERWORKS, INC.

ORIGINAL RULE NO. 8

SERVICE CONNECTION

Page 1 of 1

A. The Company shall determine the point of service to any premises. The Company shall be called upon for exact information regarding the service entrance before any piping in the interior of the building has been started. If such information is not secured, expensive changes in piping installation may result for which the Company shall not be held liable in any way and will not assume any responsibility.

B. Not more than one service line shall be installed on the premises for any one customer unless agreed to by the Company where special circumstances exist.

C. No more than one single family residential unit shall be served through any single domestic water service connection. In the case of multiple dwelling units or condominiums, service can be rendered by a single connection or by individual meters for each dwelling unit at the option of the owner.

D. Company's service laterals shall terminate at the property line and it shall be the owner's responsibility and at the owner's expense to install a stop and waste valve and to make the necessary connection from the Company's service lateral to the building or buildings to be served. For those systems providing fire protection, the customer shall install a pressure regulating device.

E. Company will endeavor to install meters as close as possible to the property line provided there is public access to the meter location.

EFFECTIVE

FOR SERVICE ON


JAN 28 1992

BY F.O. Case No. 2347

APPROVED

New Mexico Public Service Commission

Advice Notice No. 2

Signature/Title  President